



2810 Clark Avenue • St. Louis, MO 63103-2574 • (314) 531-8080 • FAX (314) 531-8085
Chemical, Metallurgical, Mechanical, Nondestructive, Environmental Testing, Analyses and Field Service.

SCALE FREE SYSTEMS, INC.
325 Sun Valley Circle
Fenton, MO 63026

September 13, 2010
Lab No. 10E-1566
Invoice No. 124620
P.O. No. Maryland Heights/MM
Page 1 of 1

Attention: Joe Miller

REPORT OF TESTS

SAMPLE ID: WATER SAMPLE, MARYLAND HEIGHTS, 9/8/10, 12:00 P.M.
Equipment- BAC 250 Ton Cooling Tower

Units: CFU/mL

ANALYTE	RESULTS	MQL	TEST METHOD	DATE OF ANALYSIS
Total Bacteria	329	2	Simplate	09/10/10

MQL: Minimum Quantitative Limit
ND: None Detected Above MQL

CFU: Colony Forming Units

Start Time of Incubation: 9/8/10 @ 3:10 P.M.

EPA maximum contaminant Level (MCL) for Total Bacteria (HPC) in public drinking water is 500 CFU/mL

SR/krd


Steve Root, Manager
Environmental Testing